

Operations Report

Hickory Log Creek Board of Managers Meeting

April 17, 2026

Reservoir Update

- Since February 6, 2026
 - Pumpage to the reservoir: 0.00 MG
 - Releases from the reservoir: 00.00 MG
- Current elevation: 1060.0 MSL
 - Full pool is 1060.0 MSL

HLC Asset Renewal and Replacement (AR&R) Planning

- SCADA server and software upgrade:
 - This project will continue through 2026. CCMWA Instrumentation staff have begun integration.
- Intake vault improvement:
 - All bids have been rejected due to the budget. CCMWA staff will re-bid this project after updating the scope of work. The project will be delayed until the grant is approved or denied.

Other Information

The Georgia Safe Dams Program conducted its routine quality-assurance inspections on January 15, 2026. On February 18, 2026, the program provided its report to CCMWA. The report noted no major problems.

Joe Powell Services performed quarterly PMs on the HVAC unit at the pump station.

CCMWA Instrumentation and Controls staff are ordering new probes for the spillway sonde.

Cleveland Electric completed PMs on the electrical switchgear at the pump station on March 25th and 26th. The PMs are scheduled for every two years.

Annual backflow testing on the meter at the pump station was completed in February.

New LED lighting has been installed inside the dam.

CCMWA maintenance has installed a new exhaust fan inside the dam.

Nixon Power completed the annual PM on the backup generator. During the service, it was noted that the automatic transfer switch was not functioning properly. Nixon Power staff are ordering the necessary parts to complete the repairs.

Operations Report

Hickory Log Creek Board of Managers Meeting

April 17, 2026