

Operations Report

Hickory Log Creek Board of Managers Meeting
May 29, 2025

Reservoir Update

- Since April 16, 2025
 - Pumpage to the reservoir: 0.00 MG
 - Releases from the reservoir: 00.00 MG
- Current elevation: 1060.0 MSL
 - Full pool is 1060.0 MSL

HLC Asset Renewal and Replacement (AR&R) Planning

- SCADA server and software upgrade:
 - This project has been delayed and will continue through 2025.
- Intake vault improvement:
 - All bids have been rejected due to the budget. CCMWA staff will re-bid this project after updating the scope of work. The project will be rebid later pending budget approval.
- Instrumentation replacement:
 - Schnabel is collaborating with CCMWA staff to utilize contractors selected as subcontractors under CCMWA in an effort to reduce project costs. A Task Authorization has been signed. Project start date TBD.

Other Information

Joe Powell Services has completed the quarterly HVAC PMs at the pump station

CCMWA Instrumentation and Controls removed the downstream Sonde for repairs. The Sonde has been reinstalled, and all repairs were covered under warranty.

CCMWA Instrumentation and Controls completed quarterly Sonde PMs.

HLC staff completed lubrication PMs on the 42" and 24" ring jet valves.

HLC staff attended the Cherokee County EMA Category 1 Dam Orientation Workshop. Members of Cherokee EMA participated in a full tour of HLC on May 27

On May 8, Schnabel completed the Full inspection for Q2 of the dam.

Operations Report

Hickory Log Creek Board of Managers Meeting

May 29, 2025